




Cumulocity Agent

APPLICATION NOTE



ADVANTECH

Used symbols



Danger – Information regarding user safety or potential damage to the router.



Attention – Problems that can arise in specific situations.



Information, notice – Useful tips or information of special interest.



Example – Example of function, command or script.



Contents

1	User Module Cumulocity Agent	1
1.1	Description	1
1.2	Installation	2
1.3	Configuration	3
1.3.1	Monitoring	6
1.3.2	Logs download	6
1.3.3	Remote restart	8
1.3.4	Remote install	9
1.3.5	Config management	11
1.3.6	Modbus support	12
1.3.7	Telling geolocation	16
1.4	Status	17
1.5	LUA script	18
1.5.1	Example #1: Measurement	18
1.5.2	Example #2: Shell commands handling	19
1.5.3	LUA c8y object	21
2	Cloud Administration	23
2.1	Cloud Account	23
2.2	Device Registration	24
2.3	Device Information	25
3	FAQ	26
4	Licenses	27
5	Related Documents	28

List of Figures

1	Routers Connected to Cumulocity Cloud Service via Cumulocity Agent	1
2	Main Menu	2
3	Configuration of <i>Cumulocity Agent</i> User Module	3
4	Get the Server Address	4
5	Items of the <i>Cumulocity Agent</i> configuration	5
6	Measurements	6
7	Device monitoring	6
8	Log download	7
9	Log record	7
10	Remote restart	8
11	Restart device record	8
12	Add software	9
13	Record of sucessful software install	9
14	Record with failed software install	10
15	Remote install	10
16	Configuration	11
17	Config record	11
18	Configuration	12
19	Subscribed applications	12
20	Device protocols	13
21	Modbus protocol functionalities	13
22	Modbus child devices	14
23	Cockpit	14
24	Modbus menu	15
25	Child device alarm	15
26	Cockpit widget	16
27	Geolocation	16
28	Daemon Status	17
29	Cumulocity Cloud Login	23
30	Device Registration	24
31	Confirmation of the Device Registration	24
32	Device in the All Device List	25
33	Device Information	25
29	licenses	27

1. Router App Cumulocity Agent

1.1 Description



This Router app is not contained in the standard router firmware. Uploading of this router app is described in the Configuration manual (see Chapter [Related Documents](#)).



Due to its space requirements there is no support for Geolocation and LUA scripts with platform V2.



For more information about Cumulocity service, see the Cumulocity online guides at <https://www.softwareag.cloud/site/dev-center/cumulocity-iot.html#/>.

Cumulocity service is a cloud-based subscription service designed for creating Internet of Things (IoT) solutions. It gives you very fast visibility and control over your remote devices. Cumulocity works with any network architecture, but it is specifically designed to work out of the box with mobile networks, therefore it is an ideal solution for Advantech routers.

Cumulocity stores all information about your devices (routers) on one place and displays it in a visual form through the web interface. The *Cumulocity Agent* router app allows you to monitor and store information about Advantech routers.




Figure 1: Routers Connected to Cumulocity Cloud Service via Cumulocity Agent

Cumulocity Agent router app installed in the router communicates with the Cumulocity cloud server secured by HTTPs or MQTTs. Immediately after connecting the router to the Cumulocity cloud, basic information about the router is available. At the same time Cumulocity starts to create statistics about the signal strength and other parameters.

Cumulocity router app makes these router information accessible through Cumulocity:

- Basic information about the router (name, type, model, serial number, IMEI etc.).
- Graphs of measurements and statistics – signal strength, router's memory usage and data traffic.

1.2 Installation

The latest version of *Cumulocity Agent* router app can be downloaded from the Engineering Portal [EP] at <https://icr.advantech.cz/products/software/user-modules#cumulocity>.

In the GUI of the router navigate to *Customization* -> *Router apps* page. Here choose the downloaded module's installation file and click to the *Add or Update* button.

Once the installation of the module is complete, the module's GUI can be invoked by clicking the module name on the *Router Apps* page. In Figure 2 is shown the main menu of the module. It contains the *Status* menu section, followed by the *Configuration* and *General* menu sections. To return back to the router's web GUI, click on *Return* item.

Cumulocity Agent

Status
Daemon status
System Log
Configuration
Global
General
Licenses
Return

Figure 2: Main Menu

1.3 Configuration

Configuration of the *Cumulocity* router app is accessible through the web interface of the router in section *Router Apps*. Click on the *Cumulocity Agent* -> *Configuration* -> *Global* and you will see the configuration page as shown in Figure 3.

Figure 3: Configuration of *Cumulocity Agent* Router App

To get the server address, log in to the Cululocity cloud (see Chapter 2) and copy the part of URL address as shown on Figure 4.



Adding the router to Cumulocity cloud can be done from the Cumulocity web interface and is described in Chapter 2. To add the router, you just need to know the *Device ID* of the router.




Figure 4: Get the Server Address

In the table below are described all items from user's module configuration page.

Item	Description
Enable Cumulocity Agent	Enables the Cumulocity Agent router app.
Protocol	Choose the communication protocol, MQTTs or HTTPs . Both protocols are forced to use secure connection only, HTTPs uses port 443 , MQTTs uses port 8883 . These ports are enabled on the router automatically. Ensure they are enabled for the rest of the infrastructure as well.
Server	Address of the Cumulocity cloud server without the "http" prefix, for example <i>yourURL.eu-latest.cumulocity.com</i> . Note that this address may differ for another region.
Device ID	ID of the device which is used as a unique identifier. There are these options: <ul style="list-style-type: none"> • Serial number – serial number of the device. • Cellular IMEI – IMEI of the 1st cellular module. • LAN MAC – LAN MAC address of the 1st Ethernet (eth0). • Own string – custom ID, ensure the uniqueness!
Log level	Choose a level for the logging. Available levels are: Critical, Error, Warning, Notice, Info and Debug.
Enable monitoring	Enables monitoring of cellular signal strength, power supply voltage, storage, temperature, memory and CPU.
Monitoring interval	Interval for the monitoring.
Enable logs download	Enables the server to download logs (dmesg, main log messages and modules logs) from the device.
Enable remote restart	Enables the server to initiate the device restart remotely.
Enable remote install	Enables the Cumulocity server to install modules or firmware to the device. Installation resources can be managed in the Management section. Direct link to a package on the Engineering Portal [EP] can be declared here.

Continued on the next page

Continued from previous page

Item	Description
Enable config management	Enables the server to get the configuration of the device.
Config include users	The configuration gained from the device remotely will include information about local users, including their credentials.
Enable Modbus support	Enables the communication with Modbus devices
Port, Baud rate, Parity, Stop bits, Transmit rate, Polling rate	Modbus communication settings
Allow remote config	Settings can be changed in cloud
Allow write operations	This option needs to be checked when we want to write from cloud to Modbus devices via router (otherwise the data will be rejected by router)
Enable tell geolocation ¹	Enables the server to gain the device location remotely. It is functional for the routers having a GNSS module only.
LUA script ¹	This is an optional script that will be executed during the agent start. The length of this script is limited by 12000 characters. For more information see Chapter 1.5.

Figure 5: Items of the *Cumulocity Agent* configuration



Most of the options will be described in detail later in this document.

¹Not supported on routers of v2 production platform.

1.3.1 Monitoring

Enables monitoring of cellular signal strength, power supply voltage, free space on system and user part of storage, device temperature, total and used memory, CPU usage in selected device under *Measurements* menu item.




Figure 6: Measurements

Monitoring interval is value in seconds which determines how often the monitored values are sent to cloud.




Figure 7: Device monitoring

1.3.2 Logs download

Enables the server to download logs (dmesg, main log messages and modules logs) from the device. When this checkbox is checked, menu item *Logs* appears. Then you are able to

request log file with your own criteria and parameters. When log file is ready, you can simply download log file. When rotated log is available it will join with actual log while downloading so the customer gets one continuous log file.




Figure 8: Log download

When log is requested, record with result of this action appears under the Control menu item.




Figure 9: Log record

1.3.3 Remote restart

Enables the server to initiate the device restart remotely. When checkbox is checked you can find the *Restart device* item under *More...* dropdown menu.




Figure 10: Remote restart

When restart is requested, record of this action appears under the Control menu item.




Figure 11: Restart device record

1.3.4 Remote install

Enables the Cumulocity server to install router apps (software) or firmware to the device. Installation resources can be managed in the Management section. You can select adding software to repository by upload binary file or by providing URL to software archive. Direct link to a package on the Engineering Portal [EP] can be declared here.




Figure 12: Add software

After adding desired software (or firmware) it is ready for install. Software installation is handled in the Devices Management / Devices / All devices / *your_router* / Software.

In case of adding firmware, there is possibility to upload whole package or even single *.bin file.



When adding software via URL with secure https protocol, you need to upload certificates as described in the FAQ in [chapter 3](#). In case of installing directly from Engineering Portal the certificate is part of the package.

When software is installed or uninstalled, record with result of this action appears under the Control menu item.




Figure 13: Record of successful software install




Figure 14: Record with failed software install




Figure 15: Remote install

1.3.5 Config management

Enables the server to get the configuration of the device. When checkbox is checked you can find *Configuration* menu item in the Devices Management / Devices / All devices / *your_router* / Configuration.




Figure 16: Configuration

Config include users means, that we could read list of the users and password hashes from downloaded config. That option might not be wanted due to security reasons.

When config is retrieved, record with result of this action appears under the Control menu item.




Figure 17: Config record

1.3.6 Modbus support

Enables the Cumulocity server to connect to the Modbus devices.




Figure 18: Configuration



For Modbus to work, you have to have Cumulocity full account and have Fieldbus activated in the Administration / Subscribed applications




Figure 19: Subscribed applications

Port, Baud rate, Parity, Stop bits applies only for connection to Modbus via RS-485 or RS-232. Check the serial communication settings of the device according to the instructions provided with the Modbus device. These have to match with all devices on the bus.

Transmit rate declared how often are data send to cloud.

Polling rate says how often are data read from Modbus devices.

Transmit rate cannot be lower than polling rate. You might want to read data significantly more often, because there can be alarms etc. binded to that value. For example in case of water level sensor you might not want detailed records, but when water level rises too much, you need to react fast with alarm.

To define what data you want to get via Modbus, you have to register device registers in Device types / Device protocols. Once you define this definition, you can use it in multiple devices without the need of registering needed registers all over again for other devices.




Figure 20: Device protocols

In this protocol you define binary coils/discrete inputs or value holding registers/input register (as usual for Modbus). But be aware, that there is write option even for discrete inputs/input registers. If you allow write (update in their terminology) you have to check "Allow write operations" on your router, otherwise the router reject those.

In protocol definition there are 3 switches:

- **Send measurements** – values received from Modbus device are taken as measurement data and will be displayed as graph.
- **Raise alarm** – If value is not zero, then alarm is raised.
- **Send event** – If value changes, alarm is registered.





Figure 21: Modbus protocol functionalities



STATUS	NAME	MODEL	SERIAL NUMBER	REGISTRATION DATE	SYSTEM ID	IMEI	ALARMS
	adam 6256			19 November 2020 10:31	909246		
	adam 6251			19 November 2020 10:31	909342		1 ●

Figure 22: Modbus child devices

Results from those 3 switches are found in the Child devices menu item.

Remaining 2 options are:

- **Show status** – Displays value in widget.
- **Update status** – Value can be changed in widget and this value is written to modbus device (as mentioned before, *Allow write operations* has to be allowed on the router).

Results of those two remaining options can be seen in the Cockpit. Fieldbus device widget needs to be added to the cockpit.




Figure 23: Cockpit

Now, when protocols are defined, we could go to the devices Modbus menu where we could add TCP and RTU devices by entering addresses and choosing protocol defined before.




Figure 24: Modbus menu

As we mentioned before, results of our effort could be seen in *Child devices* and *Cockpit*




Figure 25: Child device alarm




Figure 26: Cockpit widget

1.3.7 Telling geolocation

Enables the server to gain the device location remotely. It is functional for the routers having a GNSS module only. Map in the lower right corner in the selected device shows current location.




Figure 27: Geolocation



Due to its space requirements there is no support for Geolocation and LUA scripts with platform V2.

1.4 Status

The status of the daemon and agent running on the device can be observed on the *Daemon status* page, see Figure 28.




Figure 28: Daemon Status

There are following information that may appear on this page:

- Daemon is **RUNNING** / **NOT RUNNING** - Tells if the daemon process of the agent is running or not.
- Agent is **CONNECTED** / **NOT CONNECTED** - Tells if the network communication between the router and cloud is established or not.
- Router is **INTEGRATED** / **NOT INTEGRATED** - Tells if the router is registered and accepted on the cloud or not. If so, it will get the device ID.

The next status page called *System Log* displays the log of the router which is the same as *System Log* in the *Status* section of router's configuration.

1.5 LUA script

LUA script can be used to start a timer for a periodic task (e.g for sending of measurements) or to register a messages handler for cloud requests.

The length of the script is limited by 12000 characters. You can get around this limitation with splitting code to the modules and then load this module via `require()` command. LUA searches the modules in `/usr/lib/lua_modules` folder. You can also put third-party LUA modules to this folder or install some our router modules with LUA modules (e.g. *lua-libmodbus* for Modbus support in LUA scripts).

Every LUA script should have an `init()` function, which is processed on the module start. When this function finishes successfully, it must return 0, otherwise, a non-zero value.

A proprietary *SmartREST* protocol is used for a between the communication device and Cumulocity cloud. It is a standard REST protocol optimized for small data transfers. The message templates are used for this purpose. Each message template contains a REST query with variables. All templates are sent to a Cumulocity server and a future communication contains only values for variables. The server complete from the template and this values a final REST query. See official documentation for [SmartREST](#) details.

You can find the module's built-in message templates in `/opt/cumulocity/etc/srtemplate`. If you need the other template, put it to `/var/data/cumulocity/srtemplate`. The first line must contain a unique identifier. Use numbers between 900 and 999 for your messages to avoid conflicts with the module's built-in messages in the future. See the second example in Chapter 1.5.2 for details.



Due to its space requirements there is no support for Geolocation and LUA scripts with platform V2.

1.5.1 Example #1: Measurement



LUA script in this example is compatible with Cumulocity version 2.0.1.

The script below regularly sends the number of connected AP clients. For testing, you must define AP on a router and connect to it with some clients.

```
function init()
    timer = c8y:addTimer(1*10000, 'sendStat')
    timer:start()
    return 0
end

function sendStat()
    local file = io.popen('iw dev wlan0 station dump | grep Station | wc -l')
    local count = file:read('*n')
    file:close()
    c8y:send('200,' .. c8y.ID .. ',WifiAccessPoint,WifiAccessPoint,Clients,' .. count
        .. ',')
end
```

The `init()` function starts a timer which calls the `sendStat()` function in 10 seconds interval. The `sendStat()` function looks for the number of AP clients and sends this value to the cloud. It uses a built-in message 200 for a general measurement. See official [documentation for Measurements](#).

1.5.2 Example #2: Shell commands handling



LUA script in this example is compatible with Cumulocity version 2.0.1.

This script waits for the shell commands from the Cumulocity server, executes it and returns results. This example needs other messages. Create file `/var/data/cumulocity/srtemplate` with following content:

```
lua_examples
11,901,,$.c8y_Command,$.id,$.deviceId,$.c8y_Command.text
10,902,PUT,/devicecontrol/operations/%%,application/json,%%,UNSIGNED STRING STRING
STRING,{"status":"%%","c8y_Command":{"text":"%%","result":"%%"}}
```

The first line is a unique identifier. The second line is a definition of receiving requests. The third line is a definition for the sending of responses.

```
function init()
    c8y:addMsgHandler(901, 'shell')
    c8y:send('103,' .. c8y.ID .. ', ""c8y_Command""c8y_Restart""c8y_LogfileRequest""')
    return 0
end

function run(cl)
    local output
    local file = io.popen(cl)
    if file then
        output = file:read('*a')
        file:close()
    end
    return output
end

function shell(r)
    local operID, devID, command = r:value(2), r:value(3), r:value(4)
    local cmd, arg = command:match('(%S+)%s+([%a%d%.%-]+)')
    if cmd ~= 'ping' and cmd ~= 'traceroute' or not arg then
        c8y:send('105,' .. operID .. ', "Not supported command"')
        return
    end
    if cmd == 'ping' then
        command = 'ping -c 3 ' .. arg
    end
end
```

```

c8y:send('104,' .. operID .. ',EXECUTING')
local output = run(command)

if output then
    output = output:gsub("'", '"'):gsub('\n', '\\n')
    c8y:send('902,' .. operID .. ',SUCCESSFUL,"' .. r:value(4)
.. '"',"' .. output .. '"')
    c8y:send('104,' .. operID .. ',SUCCESSFUL')
else
    c8y:send('105,' .. operID .. ',Can not execute command')
end
end
end

```

The `init()` function register a handler for the requests containing shell commands. The server needs to know which functionality the router supports. The second line in `init()` sends this information. As it overwrites a previous definition, you must repeat the capabilities previously send by module core. You can find it in the log with debug log level set as shown below.

```

2019-11-27 17:41:18 cumulocity[12290]: HTTP post: 15,9491 111,4581,"358709050508492,
358709050508492",,"8942001210298048298, 8942001210298048298" 115,4581,{"name
": "Cumulocity Agent", "version": "2.0.0 (2019-06-10)", "url": ""}, {"name
": "GDB", "version": "1.0.0 (2015-04-30)", "url": ""}, {"name": "GPS", "
version": "1.6.4 (2019-03-27)", "url": ""}, {"name": "Node-RED", "version
": "2.0.0 (2019-09-19)", "url": ""}, {"name": "Node-RED / FTP", "version
": "2.0.0 (2019-10-04)", "url": ""}, {"name": "Node-RED / Modbus", "version
": "2.0.0 (2019-10-04)", "url": ""}, {"name": "Node-RED / Splunk event
collector", "version": "1.0.1 (2019-03-22)", "url": ""}, {"name": "Node.js
", "version": "2.0.0 (2019-09-19)", "url": ""} 106,4581,"dmesg", "
messages", "module-nodered" 103,4581,"c8y_Restart","c8y_LogfileRequest"
201,4581,0 202,4581,499,21.3 203,4581,77.8,73.9 204,4581,39 205,4581,11.4

```

The `shell()` function registered to handler cares for the shell command processing. Its argument contains data from the request, see the *Message Handler* in Chapter 1.5.3. A next part parses the received command. Remember this functionality is a potential security risk. So this example limits available commands to ping and traceroute only with one IP or domain argument and no options. Script change operation state on the server before executing. If execution is successful, the script returns a result. Then it closes operation on both cases successful and failure.

1.5.3 LUA c8y object

All LUA scripts have access to a c8y object. This object expose timers, SmartREST message based callbacks, HTTP binary APIs.

Timer

A timer provides periodical execution of a Lua function. Related APIs are as following:

- `c8y:addTimer(interval, callback) -> timer`

Create a timer object with a time period of interval milliseconds. The Lua function with the name equals to the string callback will be executed when the timer fires. A timer is inactive when first created.

- `timer:start()`

Start a timer object. timer becomes active.

- `timer:stop()`

Stop a timer object. timer becomes inactive.

- `timer.isActive`

Boolean property indicating whether the timer is active or not.

- `timer.interval`

A property of the timer object. Read this property to get the current period of this timer. Write this property to set a new period for this timer. Setting a timer's interval to 0 is undefined behaviour.

Message Handler

A message handler is a SmartREST message callback, which is executed when a message for the registered SmartREST template ID is received.

- `c8y:addMsgHandler(MsgID, callback)`

Register a message callback for message ID MsgID. The Lua function with the name equals to the string callback is executed when a message with ID MsgID is received. The callback function is called with a single SmartREST record parameter, see below about the record object APIs. Calling this function multiple times with the same MsgID overwrites the callback function.

- `record.size`

Read-only property denotes the number of the tokens in the record.

- `record:value(i) -> string`

Return the value of the token at position i. Index i starts from 0.

- `record:type(i) -> int`

Return the type of the token at position i. Index i starts from 0.

Networking

- `c8y:send(request, prio)`

Send request to Cumulocity. Note this is asynchronous sending, this function returns immediately without any guarantee whether the request is sent successful or not. Set prio to 1 if you want the guarantee. Calling this function without prio or with prio equals 0 is the same default no guarantee sending. Be careful not to abuse the prio parameter, as there is a capacity for buffering failed requests, old requests will be discarded when this capacity is reached.

- `c8y:post(dest, ct, data) -> int`

HTTP multipart POST to upload a binary to Cumulocity. `dest` is the file name to be stored on the server. `ct` is the Content-Type of data. `data` contains the actual content to be posted. This function is synchronous, on success, it returns the size of the response, on failure, -1 is returned.

- `c8y:postf(dest, ct, file) -> int`

Counterpart of the `post` function that instead of asking the caller to read the data, the actual content to be posted is in a file pointed by parameter `file`. This function is also suitable when the file is large and can not be read once all in the memory. This function also returns -1 when read file failed.

- `c8y:get(id) -> int`

HTTP GET method to download a binary from Cumulocity. `id` is the unique resource identifier of the binary. This function is synchronous, on success, it returns the size of the response, on failure, -1 is returned.

- `c8y:getf(id, dest) -> int`

Counterpart of the `get` function, which instead of download a binary to memory, rather store the binary in a file pointed by `dest`. On success, the function returns the number of bytes written so far, on failure, the function returns -1. Note this function overwrites the file named `dest` if it exists.

- `c8y.resp`

Read-only property stores the server response for `post`, `postf` and `get`. The content of `c8y.resp` is undefined when these functions failed.

Misc

- `c8y.server`

Server address the agent connects to.

- `c8y.ID`

The managed object ID for the agent.

2. Cloud Administration

2.1 Cloud Account

Login to your Cumulocity account at <https://yourURL.softwareag.cloud/mycloud>, where *yourURL* is your domain set up during the registration.

If you don't have an account yet, create one at <https://www.softwareag.cloud/site/product/cumulocity-iot.html#/>, in the upper right corner click on *Try for free*. Then wait for the confirmation email and login to your cloud account at the address sent in this email. When logged in to the Cumulocity, choose the Cumulocity cloud product, as shown in Figure 29.




Figure 29: Cumulocity Cloud Login

2.2 Device Registration

To register a new device to the Cumulocity cloud go to *Devices -> Registration* section and follow the steps shown in Figure 30. Fill in the router's Device ID identically with the Device ID declared in Cumulocity Agent installed on the device.




Figure 30: Device Registration

The device will appear in the list of devices with *waiting for connection* status. Cumulocity Agent has to be running and configured properly on the device to finish the registration successfully. Ensure that the device is connected to the Internet. Note, that the Cumulocity Agent may stop after some unsuccessful connection attempts. In a while, the status of the devices will change to *pending acceptance* and the *Accept* button will be available, see Figure 31. Click this button and the registration of the device is done.





Figure 31: Confirmation of the Device Registration

2.3 Device Information

The successfully registered device is present in the *All devices* section, see Figure 32. It can take a few seconds prior to the device will appear in the list after clicking the acceptance.




STATUS	NAME	MODEL	SERIAL NUMBER
	Router (SmartFlex#1)	SPECTRE-v3-LTE	6200010
	Router (SmartFlex#11)	SPECTRE-v3-LTE	6200011

Figure 32: Device in the All Device List

Clicking a device in the *All devices* list, the basic information about the device appears, see Figure 33. There is information about the device name, type, model, serial number, ICCID, IMEI, etc. Some of this information can be edited here as well.

There are some other pages for the device administration, for example, Alarms, Control, Software, Events, Location or Logs as shown in Figure 33. Note that displayed device data and administration pages depend on the configuration made in the Cumulocity Agent on the device.



DEVICE STATUS	
 Send connection: online Push connection: active Last communication 25 November 2019 10:11	
Required interval	5 minutes
Maintenance	<input type="checkbox"/>
Owner	<input checked="" type="checkbox"/> device_Smar...

DEVICE DATA	
ID	668
Name	Router (SmartFlex#1)
Type	c8y_cumulocity_agent
Last updated	2019-11-25T09:15:45.560Z

AVAILABILITY	
Status	UNAVAILABLE
Last message	2019-11-25T09:11:46.900Z

CONNECTION	
Status	CONNECTED

FIRMWARE	
Name	SPECTRE-v3-LTE.bin
Version	6.2.2 (2019-11-19) BETA #621

HARDWARE	
Model	SPECTRE-v3-LTE
Serial number	6200010

DEVICE DATA	
ID	668
Name	Router (SmartFlex#1)
Type	c8y_cumulocity_agent
Last updated	2019-11-25T09:15:45.560Z

Figure 33: Device Information

3. FAQ

Required Certificates

If you define a repository with HTTPs sources in the Cumulocity cloud, you need the Root CA certificates on the router to be able to download data from this source. These certificates or symlinks to them should be located in `/opt/cumulocity/etc/certs` directory having the name by hash (see `c_rehash` OpenSSL tool).

Where is Network Card Information on Cumulocity Website?

The router has very complex network settings and the default Cumulocity network plugin is very simple so it cannot reflect the whole router's networking.

Files with Credentials

Router agent stores credentials into `/var/data/cumulocity/credentials`. If required, these credentials can be deleted or backed-up eventually. This file is deleted while the module is being uninstalled.

Device ID was changed

If the device ID, which already was registered to the cloud, was changed, the device won't be able to connect to the cloud. To fix this issue delete the credentials file located here: `/var/data/cumulocity/credentials`.

I can't see Modbus menu item even if I have checked *Enable Modbus support*

Make sure you have subscribed Fieldbus application (feature-fieldbus4) in Administration/Applications/Subscribed applications

4. Licenses

Summarizes Open-Source Software (OSS) licenses used by this module.

Cumulocity Agent Licenses		
Project	License	More Information
Cumulocity C SDK	MIT	License
CURL library	MIT style	License
LUA library	MIT	License
gpsd library	BSD	License
OpenSSL library	BSD style	License

Figure 29: licenses

5. Related Documents

You can obtain product-related documents on *Engineering Portal* at icr.advantech.cz address.

To get your router's *Quick Start Guide*, *User Manual*, *Configuration Manual*, or *Firmware* go to the [Router Models](#) page, find the required model, and switch to the *Manuals* or *Firmware* tab, respectively.

The *Router Apps* installation packages and manuals are available on the [Router Apps](#) page.

For the *Development Documents*, go to the [DevZone](#) page.