



Ref. Certif. No.

DK-126032-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Din-Rail Switching Power Supply

Name and address of the applicant

MEAN WELL ENTERPRISES CO LTD
NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891
TAIWAN

Name and address of the manufacturer

MEAN WELL ENTERPRISES CO LTD
NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891
TAIWAN

Name and address of the factory

MEAN WELL ENTERPRISES CO LTD
NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891
TAIWAN

Note: When more than one factory, please report on page 2

☒ [Additional Information on page 2](#)

Ratings and principal characteristics

Input:100 - 277 Vac, 2.8A, 50/60 Hz

☒ [Additional Information on page 2](#)

Trademark (if any)

MEAN WELL



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

DRS-240-x (where x can be 12, 24, 36, 48 which denoted for output voltage)

Additional information (if necessary may also be reported on page 2)

Additionally evaluated to:

EN IEC 62368-1:2020, EN IEC 62368-1:2020/A11:2020

National Difference specified in the CB Test Report

☐ [Additional Information on page 2](#)

A sample of the product was tested and found to be in conformity with

IEC 62368-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

E183223-A6075-CB-1 issued on 2022-04-06

This CB Test Certificate is issued by the National Certification Body



- ☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☒ UL (Denko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2022-04-07

Signature:

Jan-Erik Storgaard



Ref. Certif. No.

DK-126032-UL

Factory(ies):

SUZHOU MEAN WELL TECHNOLOGY CO LTD

NO. 77, JIAN-MIN ROAD DONG-QIAO PAN-YANG IND. PARK HUANG-DAI TOWN XIANG-CHENG DISTRICT SUZHOU
JIANGSU 215152 CHINA

MEAN WELL (GUANGZHOU) ELECTRONICS CO LTD

NO 11 JINGU SOUTH ROAD HUADU DISTRICT GUANGZHOU GUANGDONG 510890
CHINA

YONGDEN TECHNOLOGY CORPORATION

345 MACARTHUR HIGHWAY TABANG, GUIGUINTO, BULACAN 3015,
PHILIPPINES

Additional Ratings:

Model DRS-240-12:

Input:100 - 277 Vac, 2.8A, 50/60 Hz

Output: 12 Vdc, Max. 20 A

BAT.: 12 Vdc, Max.15.4 A

Total Power: Max. 240 W

Model DRS-240-24:

Input:100 - 277 Vac, 2.8A, 50/60 Hz

Output: 24 Vdc, Max. 10 A

BAT.: 24 Vdc, Max. 7.7 A

Total Power: Max. 240 W

Model DRS-240-36:

Input:100 - 277 Vac, 2.8A, 50/60 Hz

Output: 36 Vdc, Max. 6.67 A

BAT.: 36 Vdc, Max. 5.1 A

Total Power: Max. 240 W

Model DRS-240-48:

Input:100 - 277 Vac, 2.8A, 50/60 Hz

Output: 48 Vdc, Max. 5 A

BAT.: 48 Vdc, Max. 3.85 A

Total Power: Max. 240 W

Additional information (if necessary)



☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

☒ UL (Denko), Borupvang 5A DK-2750 Ballerup, DENMARK

☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2022-04-07

Signature:

Jan-Erik Storgaard