

Verification of Compliance

Product Name : 480W Single Output Industrial DIN RAIL Power Supply
Brand Name : MEAN WELL
Model Number : NDR-480-x(x=24, 48)
Applicant : MEAN WELL ENTERPRISES CO., LTD.
Address : No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan
(R.O.C.)
Report Number : S1C-M020-1411-284
Issue Date : July 16, 2015
Applicable Standards :

Emission :

EN 55011 : 2009+A1 : 2010
Group 1, Class B
EN 55022 : 2010 Class B
EN 61000-6-3 : 2007+A1 : 2011
EN 61000-3-2 : 2014
EN 61000-3-3 : 2013
EN 61204-3:2000 Class B

Immunity :

EN 55024 : 2010
EN 61204-3 : 2000 High severity level
EN 61000-6-2 : 2005
EN 61000-4-2 : 2009
EN 61000-4-3 : 2006+A1 : 2008+A2 : 2010
EN 61000-4-4 : 2012
EN 61000-4-5 : 2006
EN 61000-4-6 : 2014
EN 61000-4-8 : 2010
EN 61000-4-11 : 2004

Based on the EMC Directive 2014/30/EU and the specifications of the customer, one sample of the designated product has been tested in our laboratory and found to be in compliance with the EMC standards cited above.



TAF 0905
FCC CAB Code TW1053
NVLAP Lab Code 200575-0
IC Code 4699A
VCCI Accep. No. R-1527, C-1609, T-1441, G-10
C-4400, G-614, T-1334



Central Research Technology Co.

EMC Test Laboratory
11, Lane41, Fushuen St., Jungshan Chiu,
Taipei, Taiwan, 104, R.O.C.
Tel : 886-2-25984568
Fax: 886-2-25984546

(Tsun-Yu Shih/ General Manager)

Date: July 16, 2015