

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product

Produit

Name and address of the applicant

Nom et adresse du demandeur

Name and address of the manufacturer

Nom et adresse du fabricant

Name and address of the factory

Nom et adresse de l'usine

Note: When more than one factory, please report on page 2

Note: Lorsque il y plus d'une usine, veuillez utiliser la deuxième page

Ratings and principal characteristics

Valeurs nominales et caractéristiques principales

Trademark (if any)

Marque de fabrique (si elle existe)

Type of Manufacturer's Testing Laboratories used

Type de programme du laboratoire d'essais constructeur

Model / Type Ref.

Ref. De type

Additional information (if necessary may also be reported on page 2)

Les informations complémentaires (si nécessaire, peuvent être indiqués sur la deuxième page)

A sample of the product was tested and found to be in conformity with

Un échantillon de ce produit a été essayé et a été considéré conforme à la

As shown in the Test Report Ref. No. which forms part of this Certificate

Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

This CB Test Certificate is issued by the National Certification Body

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

LED Driver

MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd., Wugu Dist.
New Taipei City 248
Taiwan

MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd., Wugu Dist.
New Taipei City 248
Taiwan

☒ Additional information on page 2

I/P: 100-240Vac, 5.5A, 50/60Hz. Cl. I



HLG-480H-XY, HLGP-480H-XY

DC-output: See General product information for details. IP65, IP67 or IP68, tc: 90°C, ta: 50°C for input 200-240Vac, ta: 40°C for input 100-200Vac, pf: 0.95, independent SELV, constant voltage mode. The "X" can be 24, 30, 36, 42, 48 or 54 to denote the output voltage (unit: V) (FOR HLG-480H-XY, HLGP-480H-XY). The "X" can be 24, 36, 48 or 54 for denote the output voltage (unit: V), The "Y" to denote the optional function: It can be Blank, A, B or Dx, AB or D2 for HLG-480H-XY series. It can be Blank, A, B or AB for HLGP-480H-XY series

☐ Additional information on page 2

IEC 61347-2-13:2014

IEC 61347-1:2007, IEC 61347-1:2007/AMD1:2010, IEC 61347-1:2007/AMD2:2012

324498



Gaustadalléen 30
NO-0373 Oslo, Norway

Date: 31-03-2017

Signature: Juan Z. Kleppenes
Certification Department

MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd., Wugu Dist.
New Taipei City 248
Taiwan

MEAN WELL (GUANGZHOU) ELECTRONICS CO., LTD
HUADU BRANCH
No. 11 Jingu South Road, Huadong Town, Huadu District
Guangzhou Guangdong
China

SuZhou MEAN WELL Technology Co., Ltd.
No. 77, Jian-min Road, Dong-qiao, Pan-yang Ind. Park,
Huang-dai Town Xiang-cheng District, Suzhou, Jiangsu
215152, P. R.
China



Gaustadalléen 30
NO-0373 Oslo, Norway

Date: 31-03-2017

A handwritten signature in blue ink, reading "Juan Z. Kleppenes".

Signature: Juan Z. Kleppenes
Certification Department