



中国国家强制性产品认证证书

证书编号: 2021011002393836

发证日期: 2021年06月01日

有效期至: 2026年06月01日

**认证委托人名称
及注册地址** 明纬(广州)电子有限公司
广州市天河区东圃镇黄村粤安工业园 A 栋 2 楼

**产品生产者名称
及注册地址** 明纬企业股份有限公司
新北市五股区五权三路 28 号

**生产企业名称
及生产地址** 明纬(广州)电子有限公司花都分公司
广州市花都区花东镇金谷南路 11 号

**产品名称和系列、
规格、型号** LED 模块用交流电子控制装置(LED 控制装置, 控制端口调光/非控制端口调光, 独立式, 恒流模式,
ta: 45°C, tc: 85°C, I 类, IP67, 适宜直接安装在普通可燃材料表面, 定温热保护: 110°C)
见附件。200-400V ~ 50/60Hz

**产品标准和
技术要求** GB 17625.1-2012; GB/T 17743-2017; GB 19510.1-2009; GB 19510.14-2009

上述产品符合 CNCA-C10-01:2014 认证规则的要求, 特发此证。
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发: 陆楠

中国质量认证中心





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2021011002393836

Valid from: Jun.01,2021

Valid until: Jun.01,2026

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

MEAN WELL (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District, Guangzhou, China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

MEAN WELL Enterprises Co., Ltd.
No. 28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan

**NAME AND LOCATION
OF THE FACTORY**

MEAN WELL (Guangzhou) Electronics Co., Ltd Huadu Branch
No.11 Jingu South Road, Huadong Town, Huadu District, Guangzhou, China

PRODUCT MODEL(S)

A.C. Supplied Electronic Controlgear For LED Modules (Controlled Port Dimming/Non- Controlled Port Dimming, Independent, Constant Current Mode, ta: 45°C, tc:85°C, Class I, IP67, Suitable For Direct Mounting On Normally Flammable Material, Temperature Declared Thermally Protected: 110°C)
See Appendix. 200-400V ~ 50/60Hz

**STANDARDS AND
TECHNICAL REQUIREMENTS**

GB 17625.1-2012; GB/T 17743-2017; GB 19510.1-2009; GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C10-01:2014)

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

CHINA QUALITY CERTIFICATION CENTRE





中国国家强制性产品认证证书

证书编号 2021011002393836

第 1 页 共 1 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 2849586

序号	产品型号	参数	备注
1	HVGC-650-M-AB	输出: Max. 160Vd. c. , 62-155Vd. c. , Max. 5250mA (恒流可调), 额定功率: 651W	三合一调光
2	HVGC-650-L-AB	输出: Max. 240Vd. c. , 92.8-232Vd. c. , Max. 3500mA (恒流可调), 额定功率: 650W	三合一调光
三合一调光: 1-10Vd. c. 电压信号输入调光、10Vd. c. PWM信号调光、外接电阻调光			

输入: 200-400V~50/60Hz

附件



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2021011002393841

发证日期: 2021年06月01日

有效期至: 2026年06月01日

认证委托人名称 明纬(广州)电子有限公司
及注册地址 广州市天河区东圃镇黄村粤安工业园 A 栋 2 楼

产品生产者名称 明纬企业股份有限公司
及注册地址 新北市五股区五权三路 28 号

生产企业名称 明纬(广州)电子有限公司花都分公司
及生产地址 广州市花都区花东镇金谷南路 11 号

产品名称和系列、规格、型号 LED 模块用交流电子控制装置 (LED 控制装置, 控制端口调光/非控制端口调光, 独立式, 恒流模式, 安全特低电压, ta: 45°C, tc: 85°C, I 类, IP67, 适宜直接安装在普通可燃材料表面, 定温热保护: 110°C) 见附件。200-400V ~ 50/60Hz

产品标准和 GB 17625.1-2012; GB/T 17743-2017; GB 19510.1-2009; GB 19510.14-2009
技术要求

上述产品符合 CNCA-C10-01:2014 认证规则的要求, 特发此证。
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发: 陆楠

中国质量认证中心





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2021011002393841

Valid from: Jun.01,2021

Valid until: Jun.01,2026

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

MEAN WELL (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District, Guangzhou, China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

MEAN WELL Enterprises Co., Ltd.
No. 28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan

**NAME AND LOCATION
OF THE FACTORY**

MEAN WELL (Guangzhou) Electronics Co., Ltd Huadu Branch
No.11 Jingu South Road, Huadong Town, Huadu District, Guangzhou, China

PRODUCT MODEL(S)

A.C. Supplied Electronic Controlgear For LED Modules (Controlled Port Dimming/Non- Controlled Port Dimming, Independent, Constant Current Mode, SELV, ta: 45°C, tc:85°C, Class I, IP67, Suitable For Direct Mounting On Normally Flammable Material, Temperature Declared Thermally Protected: 110°C) See Appendix. 200-400V ~ 50/60Hz

**STANDARDS AND
TECHNICAL REQUIREMENTS**

GB 17625.1-2012; GB/T 17743-2017; GB 19510.1-2009; GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C10-01:2014)

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

陆梅

CHINA QUALITY CERTIFICATION CENTRE





中国国家强制性产品认证证书

证书编号 2021011002393841

第 1 页 共 1 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 2849587

序号	产品型号	参数	备注
1	HVGC-650-U-AB	输出: Max. 70Vd. c. , 24-58Vd. c. , Max. 14000mA (恒流可调), 额定功率: 649.6W	三合一调光
2	HVGC-650-H-AB	输出: Max. 120Vd. c. , 46.4-116Vd. c. , Max. 7000mA (恒流可调), 额定功率: 649.6W	三合一调光
三合一调光: 1-10Vd. c. 电压信号输入调光、10Vd. c. PWM信号调光、外接电阻调光			

输入: 200-400V~50/60Hz

附件



中国质量认证中心