



Ref. Certif. No.

**DK-130627-UL**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product	Switching Power Supply
Name and address of the applicant	MEAN WELL ENTERPRISES CO LTD No 28 Wuquan 3rd Rd Wugu District New Taipei City 24891 Taiwan
Name and address of the manufacturer	MEAN WELL ENTERPRISES CO LTD No 28 Wuquan 3rd Rd Wugu District New Taipei City 24891 Taiwan
Name and address of the factory	MEAN WELL ENTERPRISES CO LTD No 28 Wuquan 3rd Rd Wugu District New Taipei City 24891 Taiwan
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	<input checked="" type="checkbox"/> <a href="#">Additional Information on page 2</a> For Model SHP-10K-55yz Input: 380-480VAC, 3W+PE, 13.5A, 50/60Hz Output: +55 VDC, 131A +12VSB, 1A <input checked="" type="checkbox"/> <a href="#">Additional Information on page 2</a>
Trademark (if any)	 MEAN WELL
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	SHP-10K-xyz (x=55, 115, 230 or 380; y=L or blank, z= blank, -PM or -MOD)
Additional information (if necessary may also be reported on page 2)	<b>Additionally evaluated to:</b> EN IEC 62368-1:2020, EN IEC 62368-1:2020/A11:2020 National Differences specified in the CB Test Report. <input type="checkbox"/> <a href="#">Additional Information on page 2</a>
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	E183223-A6086-CB-1 issued on 2022-08-03

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2022-08-03

Signature:

Jan-Erik Storgaard



Ref. Certif. No.

**DK-130627-UL**

**Factory(ies):**

Suzhou Mean Well Technology Co Ltd  
No. 77, Jian-min Road  
Dong-qiao Pan-yang Ind. Park  
Huang-dai Town Xiang-cheng District Suzhou, Jiangsu, 215152  
China

MEAN WELL (Guangzhou) Electronics Co Ltd  
No 11 Jingu South Road  
Huadu District Guangzhou, Guangdong, 510890  
China

YONGDEN TECHNOLOGY CORP  
345 Macarthur Hwy  
Tabang Guiguinto, Bulacan, 3015  
Philippines

**Additional Ratings:**

For Model SHP-10K-xyz (x= 115, 230 or 380)  
Input:  
380-480VAC, 3W+PE, 18.5A, 50/60Hz

Output:  
For Model SHP-10K-115yz  
+115-138VDC, max. 87A, max. 10005W  
+12VSB, 1A

For Model SHP-10K-230yz  
+216-260VDC, max. 46.3A, max. 10001W  
+12VSB, 1A

For Model SHP-10K-380yz  
+334-400VDC, max. 30A, max. 10020W,  
+12VSB, 1A

**Additional information (if necessary)**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2022-08-03

Signature:

Jan-Erik Storgaard