



Declaration of Conformity

For the following equipment :

Product Name: DIN-Rail Switching Power supply

Model Designation: DDRH-120-X (X=12,24,32,48)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

RoHS Directive (2011/65/EU), (EU)2015/863

Low Voltage Directive (2014/35/EU) :

EN 62109-1:2010

Dekra certificate No : 31-126638

Electromagnetic Compatibility Directive (2014/30/EU) :

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

EN 55032:2015+A11:2020

Class A

Harmonic current

EN IEC 61000-3-2:2019

Voltage flicker

EN 61000-3-3:2013+ A1:2019

EMS (Electro-Magnetic Susceptibility)

EN 55035:2017+A11:2020 EN IEC 61000-6-2:2019 EN IEC 61204-3:2018

ESD air

EN 61000-4-2:2009

Level 3

8KV

ESD contact

EN 61000-4-2:2009

Level 2

4KV

RF field susceptibility

EN IEC 61000-4-3:2020

Level 3

10V/m

EFT bursts

EN 61000-4-4:2012

Level 3

2KV/5KHz

Surge susceptibility

EN 61000-4-5:2014+A1:2017

Level 3

2KV/Line-Line

Conducted susceptibility

EN 61000-4-6:2014

Level 3

10V

Magnetic field immunity

EN 61000-4-8:2010

Level 4

30A/m

Note:

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Directive on the complete system again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number SC3xxxxxxx

Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Aries Jian/ Director, Group R&D :

(Name / Position)

(Signature)

Aries

Alex Tsai/Director, Product Strategy Center :

(Name / Position)

(Signature)

Taiwan

(Place)

Jan. 16, 2023

(Date)